



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-034834
Permit # 01305-2010UPG
Request Rec'd 11/17/2010
Amended Date
Approval Date 11/17/2010 JC
Permit Expires 5/17/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| (1) OWNER OF TANKS - Corporation, partnership, or other business entity: Delnor Community Hospital 300 Randall Rd Geneva, IL 60134 Contact: Dave KelpsWolf (630) 208-4271 | (2) FACILITY - name and address where tanks are located: Delnor Community Hospital 300 Randall Rd Geneva, Kane Co., IL Contact: Dave Kelps (630) 208-4271 |
|--|--|

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2) - (Installing) partial Chase Secondary Containment A.P.T. Poly Tech DCT-400 for primary product supply and return lines from main product trunk line (new transition sump) to the "south" generator, (TK # 2) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P100SC primary product supply and return lines from the main product trunk line (new transition sump) to the "south" generator.

(d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 2) - (Installing) American with Sensors/No Test Suction, (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus at the new transition sump only.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 2) - (Installing) Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

| |
|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Jan Hardy Phone: Contractor Registration # Exp. |
|---|

Sincerely,

