

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 2-029322
Permit # 01141-2010UPG
Request Rec'd 10/04/2010
Amended Date
Approval Date 10/5/2010 JC
Permit Expires 4/5/2011

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Commonwealth Edison/Exelon Corporation
3 Lincoln Center, Environmental Services Department
Oakbrook Terrace, IL 60181-4260

Contact: Art Becker (630) 947-5449

(2) FACILITY - name and address where tanks are located:

Commonwealth Edison
30000 Governors Highway
University Park, Will Co., IL

## (3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) 10,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 1) Bio-Diesel
- (e) Type of leak detection being used:

Tank:

**Piping:** (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 to replace the existing faulty sensor at the submersible sump only.

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices, piping, and dispenser containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.sfm.illinois.gov">www.sfm.illinois.gov</a> or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6)	PERSON,	FIRM OR	<b>COMPANY</b>	PERFORMING	WORK
-----	---------	---------	----------------	------------	------

Contact Person: Steve Tuttle

Phone:

James J Coffey

Contractor Registration # Exp.

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -

Division File

(Rev. - 9/10)