



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 4-003222
Permit # 01119-2010UPG
Request Rec'd 09/29/2010
Amended Date
Approval Date 9/30/2010 JC
Permit Expires 3/30/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: SNC JJ Altamont I, LLC P.O. Box 250, Effingham, IL 62401 Contact: Kathy Wines (217) 342-2205</p>	<p>(2) FACILITY - name and address where tanks are located: Jumpin Jimmy's 1206 Main Street Altamont, Effingham Co., IL Contact: Sandy Falk (618) 483-6990</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 5, 6) - 10,000 gallons, (TK # 7) - 8,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 5, 7) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX between dispensers 5/6 to 9/10 and between 7/8 to 11/12 to replace existing piping only , (TK # 6) - (Installing) partial section of Fiberglass Single Wall Piping A.O. Smith leading into the locality of, and to accommodate, new sumps for dispensers 9/10 and 11/12 only. **See contingencies section also, for further details.**
- (d) **Product to be stored in each tank:** (TK # 5, 7) - Gasoline, (TK # 6) - Diesel Fuel
- (e) **Type of leak detection being used:**
 Tank:
 Piping: (TK # 5, 6, 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 under dispensers 5/6, 7/8, 9/10, 11/12 only.
- (f) **Corrosion Protection being used:**
 Tank:
 Piping:
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	<p>Contact Person: Phone: Contractor Registration # Exp.</p>
--	---

Sincerely,

Jim Coffey

