

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 6-038964
Permit # 01118-2010UPG
Request Rec'd 09/29/2010
Amended Date
Approval Date 9/29/2010 JC
Permit Expires 3/29/2011

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

QuikTrip Corporation
4705 South 129th East Avenue
Tulsa, OK 74134

Contact: MIke Conner (918) 675-7865

(2) FACILITY - name and address where tanks are located:

QuikTrip #684
970 West Highway 50
O Fallon, St. Clair Co., IL

Contact: Brian Pendleton (314) 916-5727

## (3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) 12,000 gallons
- (b) Type of tanks:
- (c) Type of piping: The contractor will remove dispenser 5/6 from the island, then he will remove the island itself. Next, he will cut off approximately 4" of the existing dispenser sump and lower the product line riser pipes within the sumps. Then, he will re-construct the island and paving to meet ADA requirements.
- (d) Product to be stored in each tank: (TK # 1, 2, 3) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices, piping, and dispenser containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.sfm.illinois.gov">www.sfm.illinois.gov</a> or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
	Contact Person: Rick McKay Phone:
	Contractor Registration # Exp.

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -

Office Coordinator - Division File

(Rev. - 9/10)

James J Coffey