



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 7-015189
Permit # 01115-2010UPG
Request Rec'd 09/28/2010
Amended Date
Approval Date 9/29/2010 JC
Permit Expires 3/29/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Southern FS, Inc. 2002 East Main Street, P.O. Box 728 Marion, IL 62959 Contact: Doug Fox (618) 993-2833	(2) FACILITY - name and address where tanks are located: Southern FS Inc 510 West Kaskaskia Pinckneyville, Perry Co., IL Contact: Jim Howard (618) 357-9012
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6, 7, 8) - 2,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 6, 7, 8) - (Installing) partial Flexible Double Wall Environ Geo Flex from a new transition sump located before each pipe run gets to dispenser 1/2, to dispenser 1/2 where the diesel line terminates, then the two new gas line sections will continue to a new transition sump located after dispenser 1/2 - but before dispenser 3/4. A new sump will be installed under dispenser 1/2. This work is being done as a repair to damaged lines in said regions of each piping run. See the contingencies section and site plan for further details.
- (d) Product to be stored in each tank:* (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Mike Ford Phone: Contractor Registration # Exp.

Sincerely,

