



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-025081
Permit # 01101-2010UPG
Request Rec'd 09/23/2010
Amended Date
Approval Date 9/27/2010 JC
Permit Expires 3/27/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Riverdale Gas & Mini Mart, Inc. 13800 South Halsted Riverdale, IL 60827 Contact: Syed (708) 201-7866</p>	<p>(2) FACILITY - name and address where tanks are located: Clark 13800 South Halsted Riverdale, Cook Co., IL Contact: Syed (708) 201-7866</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2) - 6,000 gallons, (TK # 3, 5) - 4,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2, 3, 5) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P175SC to accommodate a "rotation" of the two eastside islands by approximately 45 degrees. Dispenser sumps are required for this "rotation" if they are not already there. This island "rotation" will effect the lines for tanks 1,2,3 only. For tank system #5, there will be a new slave dispenser installed near the existng master dispenser. This new slave dispenser will also require a sump underneath it, as well as a sump under the master dispenser.
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline, (TK # 5) - Diesel Fuel
- (e) **Type of leak detection being used:**
 Tank:
Piping: (TK # 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the new slave dispenser sump and at the existing master dispenser.
- (f) **Corrosion Protection being used:**
 Tank:
Piping: (TK # 1, 2, 3, 5) - (Installing) partial Flexible Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p align="right">Contact Person: Phone: Contractor Registration # Exp.</p>
--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File

