



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 4-020581  
Permit # 01054-2010ENT  
Request Rec'd 09/13/2010  
Amended Date  
Approval Date 9/14/2010 JC  
Permit Expires 3/14/2011

**Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Archer Daniels Midland Company P.O. Box 1470 Decatur, IL 62525  Contact: Jim Perrey (217) 424-5521	<b>(2) FACILITY</b> - name and address where tanks are located:  Archer Daniels Midland Company 1010 Airport Road Decatur, Macon Co., IL  Contact: Jim Perrey (217) 424-5521
---	--

**(3) ENTRY OF TANKS:**

(a) *Number and size of tanks being entered:* (TK # 3, 4) - 10,000 gallons

(b) *Type of tanks:*

(c) *Product stored in each tank:* (TK # 3, 4) - Jet Fuel

(d) *Reason for tanks being entered:* **Cleaning purposes.**

(e) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. **Contractor states existing manways are present, and they will be entering these tanks for cleaning.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Phone:  Contractor Registration #    Exp.
---

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)