



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-021177
Permit # 00926-2010REM
Request Rec'd 08/09/2010
Amended Date
Approval Date 8/11/2010 DS
Permit Expires 2/11/2011

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: True North Energy, LLC 5565 Airport Highway Toledo, OH 43635 Contact: Todd Tageson (216) 267-9336	(2) FACILITY - name and address where tanks are located: True North Location 1953 654 W. North Ave. Elmhurst, Du Page Co., IL Contact: Raj Patel (630) 833-2288
---	--

(3) REMOVAL OF TANKS:


- (a) Number and size of tanks being removed:* (TK # 1, 2, 3) - 10,000 gallons
- (b) Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (c) Reason of tanks being removed: Removing piping only!!!*
- (d) If tank(s) is leaking, indicate IEMA incident number:*
- (e) Date each tank was last used:* (TK # 1), (TK # 2), (TK # 3)

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

- (5) SPECIAL CONTINGENCIES:** Removing piping only!!

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Performance Tank, Inc. 730 Creel Drive	Contact Person: Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 6/07)