

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

**Division of Technical Services** 

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## Amended

FOR OFFICE USE ONLY

Facility # 4-007137
Permit # 00691-2010UPG
Request Rec'd 06/09/2010
Amended Date 08/09/2010
Approval Date 6/11/2010

Approval Date 6/11/2010 JC Permit Expires 12/11/2010

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Tri-Star Marketing, Inc. 2211 West Bradley Avenue, P.O. Box 9279 Champaign, IL 61826-9279	Mobil Super Pantry #20 507 West University Avenue Urbana, Champaign Co., IL
Contact: Kathy Delsignore (217) 367-8307 Ext. 133	Contact: Dave St. Onge (217) 328-1714

## (3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 8) 10,000 gallons, (TK # 10) 8,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 8, 10) (Installing) Flex Connector Steel. The flex connectors will be installed to replace defective ones at dispenser #2 (served by tank #8), and at dispenser 7/8 (served by tank #10), and at the tank sump for tank #10. The contractor is not doing any repairs to the double wall line outside of the tank sump for tank #10 as originally permitted.
- (d) Product to be stored in each tank: (TK # 8, 10) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration #	Exp.

James J Coffey

Sincerely,

Jim Coffev