



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-031907
Permit # 00903-2010UPG
Request Rec'd 08/02/2010
Amended Date
Approval Date 8/4/2010 JC
Permit Expires 2/4/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Federal Express Freight East 2200 Forward Drive Harrison, AR 72601 Contact: Tina Robinson (888) 465-5646	(2) FACILITY - name and address where tanks are located: Fed Ex Freight 151 Olson Drive Lincoln, Logan Co., IL Contact: Don Sebanc (217) 732-2222
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 1) - (Installing) partial Flexible Double Wall OPW Pisces primary piping from the tank submersible that leads to the first (master) dispenser, heading towards the building shop (approximately 40'). This is to replace the existing defective primary line within that region. The contractor states there is existing secondary chase piping to remain, and the run to be replaced is the longest run from the tank to a master dispenser. This appears to be the one going towards the shop - according to one of the original site plans; however, the site plans state they are "not to scale".

(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the master dispenser only (this will be the first dispenser leading towards the shop from the tank only). According to our records there are existing line leak detectors for both submersible pumps / lines, and existing sensors at these two submersible sumps.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1) - (Installing) partial Flexible Non-Corrosive within secondary chase piping.

(g) Spill containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Phone: Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -

