



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-013987
Permit # 01041-2013ABN
Request Rec'd 10/09/2013
Amended Date
Approval Date 10/9/2013 DS
Permit Expires 4/9/2014

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: M&S Transport, Inc. 3738 South Cicero Avenue Stickney, IL 60804 Contact: Bob Allen (708) 514-2191	(2) FACILITY - name and address where tanks are located: Tuxedo Junction 3738 South Cicero Avenue Stickney, Cook Co., IL Contact: Bob Allen (708) 514-2191
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 2) - 6,000 gallons, (TK # 3) - 8,300 gallons, (TK # 4) - 10,000 gallons
- (b) *Product stored in each tank:* (TK # 2, 4) - Gasoline, (TK # 3) - Diesel Fuel
- (c) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 1996-0919 Tanks are located in an existing tank field where there will be one tank that remains in service. Attempting to remove these tanks would undermine the structural integrity of existing tank.
- (d) *Location of piping being abandoned:* Piping in located in the trench with existing piping that will remain in service

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) SPECIAL CONTINGENCIES:

- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Jack Meck Phone: (630) 860-9500 Contractor Registration # IL-881 Exp. 10/27/2014
--	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)