



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

**Permit for Emergency Repair Request on
10/16/2013**

FOR OFFICE USE ONLY

Facility # 2-037019
Permit # 01053-2013UPG
Request Rec'd 10/15/2013
Amended Date
Approval Date 10/15/2013 JC
Permit Expires 10/29/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Elmhurst Memorial Hospital 200 Berteau Avenue Elmhurst, IL 60126 Contact: Tim Johnson (630) 758-8088	(2) FACILITY - name and address where tanks are located: Elmhurst Memorial Center For Health 1200 South York Rd. Elmhurst, Du Page Co., IL Contact: Tim Johnson (630) 833-1400
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 2,500 gallons
 - (b) *Type of tanks:*
 - (c) *Type of piping:* (TK # 6) - (Installing) partial section (approximately 10') Fiberglass Double Wall Ameron Dualoy 3000/LCX to repair a damaged supply line section of existing product piping.
 - (d) *Product to be stored in each tank:* (TK # 6) - Diesel Fuel
 - (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 6) - (Installing) Fiberglass Non-Corrosive
 - (g) *Spill containment devices, piping, and dispenser containment devices:*
 - (h) *Overfill prevention devices:*
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Emergency repair request was received 10/14/13. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 10/29/13.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
1111 West Dundee Road
Wheeling, IL 60090-3906

Contact Person: Larry Cherner
Phone: (847) 465-4000

Contractor Registration # IL-102 Exp. 02/07/2014

Sincerely,

Jim Coffey

