



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-024590
Permit # 01031-2013UPG
Request Rec'd 10/09/2013
Amended Date
Approval Date 10/15/2013 JC
Permit Expires 4/15/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141 Contact: Kristin Schillace (216) 338-8821	(2) FACILITY - name and address where tanks are located: True North Location 1985 2212-50 Ogden Avenue Downers Grove, Du Page Co., IL Contact: Peter Azer (630) 852-5900
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1, 2, 3) - 12,000 gallons
- (b) Type of tanks:**
- (c) Type of piping:** (TK # 1, 2, 3) - (Installing) three Submersible Sumps containment FRP, (TK # 1, 2, 3) - (Installing) eight Dispenser Sumps containment FRP, (TK # 2, 3,) - (Installing) two Transition Sumps FRP fiberglass to house ball valves to control the fuel supply to the product piping flow routes, (TK # 1, 2, 3) - (Installing) NUPI Flexible Single Wall vent Piping, (TK # 1, 2, 3) - (Installing) Flexible Double Wall NUPI Smartflex product piping that will also include two new diesel lines coming from tank #3 (for future diesel storage / dispensing) and the southeast transition valve control sump to the northeast and southeast dispensers. There will also be manifold piping for tanks 2 and 3 in conjunction with the two new valve control sumps, (TK # 2, 3) - (Installing) Positive Shutoff Valves at the two transition / ball valve control sumps located at the northwestern edge of the tank field.
- (d) Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:**
 - Piping:** (TK # 1, 2, 3) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all submersible sumps, all dispenser sumps, and at the two transition / ball valve control sumps.
- (f) Corrosion Protection being used:**
 - Tank:**
 - Piping:** (TK # 1, 2, 3) - (Installing) Flexible Non-Corrosive
- (g) Spill containment devices, piping, and dispenser containment devices:** (TK # 1, 2, 3) - (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVR
- (h) Overfill prevention devices:** (TK # 1, 2, 3) - (Installing) Overfill Drop Tube Valve OPW 71SO
- (i) Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES: See permit #01030-2013REM for the removal of the piping.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: (630) 860-9500 Contractor Registration # IL-881 Exp. 10/27/2014
---	---

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)