



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-038551  
Permit # 01058-2013UPG  
Request Rec'd 10/17/2013  
Amended Date  
Approval Date 10/17/2013 DS  
Permit Expires 4/17/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Road Ranger, LLC P.O. Box 4745, Rockford, IL 61110 Contact: Hope Collins (815) 387-1700	<b>(2) FACILITY</b> - name and address where tanks are located:  Road Ranger #266 700 King Road New Berlin, Sangamon Co., IL Contact: John Carabelli (815) 387-1700
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 10,000 gallons, (TK # 4, 5) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 2, 4) - Diesel Fuel, (TK # 5) - B-99

(e) *Type of leak detection being used:*

*Tank:* (TK # 2, 4, 5) - (Installing) Other Warren Rogers Assoc. PetroNetwork S3 CITLDS Version D

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Facilities with Warren Rogers PetroNetwork S3 (Version D) (Continual Reconciliation) tank leak detection systems must comply with the following contingencies: (1) OSFM permits must be submitted to install the Warren Rogers software and/or automatic tank gauges in all situations, and (2) Single wall tanks and double wall tanks, not using an interstitial monitoring system, must have an ATG or another approved method of tank detection that is operating in full compliance with its third party evaluation, and (3) Single wall tanks and double wall tanks, not using an interstitial monitoring system, that have a monthly throughput that exceeds the maximum allowable ATG throughput, at any time, must use the WR PetroNetwork S3 Version D system in full compliance with conditions listed in the NWGLDE evaluation. For those tanks, the WR S3 system is considered the primary method of tank leak detection and an annual precision tank tightness test is mandatory. The precision tank tightness test is required to be performed within 30 days of throughput exceeding the ATG maximum limit.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> All Line Equipment, Inc. 5519 Skyline Drive, PO Box 5257 Quincy, IL 62305	Contact Person: Steve Disselhorst Phone: (217) 224-9725 Contractor Registration # IL-002319 Exp. 12/23/2013
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)