



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-032888
Permit # 01062-2013UPG
Request Rec'd 10/17/2013
Amended Date
Approval Date 10/17/2013 JC
Permit Expires 4/17/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Andrew's Mart, Inc. 1705 Grand Avenue Beardstown, IL 62618 Contact: GoPal Basnet	(2) FACILITY - name and address where tanks are located: Andrews Mart IL Rt 104 Meredosia, Morgan Co., IL Contact: GoPal Basnet
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 8,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 4) - (Installing) submersible pump - replacing the existing suction system, (TK # 4) - (Installing) Dispenser Sumps containment FRP at the master and satellite, (TK # 4) - (Installing) Submersible Sumps containment FRP, (TK # 4) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC to replace the existing product piping to the new dispenser locations (see contingencies section).

(d) Product to be stored in each tank: (TK # 4) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 4) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350R , (TK # 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350R at the submersible sump and at the master and satellite dispenser sumps.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4) - (Installing) Flexible Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: See permit #01061-2013REM for the removal of the existing piping and suction pump / dispenser for this tank. This tank is converting to a pressurized system and relocation of the piping / dispenser.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: R. L. Hoener Company 2923 Gardner Expressway, P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: (217) 223-2190 Contractor Registration # IL-2021 Exp. 05/22/2014
--	---

Sincerely,

Jim Coffey

