



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Permit for Emergency Repair Request on 10/14/2013

### FOR OFFICE USE ONLY

Facility # 2-023831  
Permit # 01063-2013UPG  
Request Rec'd 10/17/2013  
Amended Date  
Approval Date 10/17/2013 JC  
Permit Expires 10/31/2013

### Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|  |   |
|--|---|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>The Premcor Refining Group, Inc..<br>One Valero Way<br>San Antonio, TX 78249<br><br>Contact: Craig Goecker (309) 830-2837 | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Marathon<br>44 West 322 Highway 64<br>Lily Lake, Kane Co., IL<br><br>Contact: Syed Quadri (630) 365-6200 |
|--|---|

### **(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4) - (Installing) Flex Connector Steel at the submersible sump to replace the existing leaking flex connector only.
- (d) *Product to be stored in each tank:* (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Emergency repair request was received 10/14/13. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 10/31/13.

|  |   |
|--|---|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b><br><br>Howard Lee & Sons Inc<br>4093 Perryville Road , PO Box 446<br>Cherry Valley, IL 61016 | Contact Person: John Burke<br>Phone: (815) 332-4966<br><br>Contractor Registration # IL-456 Exp. 03/20/2014 |
|--|---|

Sincerely,

Jim Coffey

