



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-012720
Permit # 01068-2013UPG
Request Rec'd 10/18/2013
Amended Date
Approval Date 10/21/2013 JC
Permit Expires 4/21/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mufaaz, Inc. 1557 South Central Avenue Cicero, IL 60804 Contact: Faisal Siddiqui	(2) FACILITY - name and address where tanks are located: Citgo 1557 South Central Avenue Cicero, Cook Co., IL Contact: Faisal Siddiqui
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 7) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 7) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX from the two existing middle diesel dispensers to the existing northeast and southeast gas dispensers only (approximately 7' each run).
- (d) *Product to be stored in each tank:* (TK # 7) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:* (TK # 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300i at the two existing diesel dispensers and at the northeast and southeast gas dispensers only.
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 7) - (Installing) partial Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Rick Krol Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 05/21/2014
---	---

Sincerely,

Jim Coffey