



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-016208
Permit # 01066-2013ABN
Request Rec'd 10/17/2013
Amended Date
Approval Date 10/31/2013 JC
Permit Expires 4/30/2014

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| (1) OWNER OF TANKS - Corporation, partnership, or other business entity: Brad Foote Gear Works 1309 S Cicero Ave Cicero, IL 60650 Contact: Iglar Michael (708) 652-7700 | (2) FACILITY - name and address where tanks are located: Brad Foote Gear Works 1309 S Cicero Ave Cicero, Cook Co., IL Contact: Iglar Michael (708) 652-7700 |
|--|--|

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1, 2, 4) - 15,000 gallons
- (b) Product stored in each tank:* (TK # 1, 2) - Used Oil, (TK # 4) - Heating Oil
- (c) Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 910375
- (d) Location of piping being abandoned:*

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES: Site assessment and certificate of site condition is on file. Abandoning tanks and piping. Using low strength concrete slurry mix. No longer in use / unable to move - inside of building. Machine access unavailable.**
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

| | |
|---|--|
| (7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> R. W. Collins Company 7225 West 66th Street Chicago, IL 60638 | Contact Person: Ann Collins Phone: (708) 458-6868 Contractor Registration # IL-772 Exp. 02/09/2014 |
|---|--|

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)