



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-005532
Permit # 01129-2013UPG
Request Rec'd 11/05/2013
Amended Date
Approval Date 11/6/2013 DS
Permit Expires 5/6/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Clear Lam Packing, Inc. 1950 Pratt Boulevard Elk Grove Village, IL 60007 Contact: Kevin Mangat (847) 439-8570	(2) FACILITY - name and address where tanks are located: Clear Lam Packing, Inc. 1950 Pratt Boulevard Elk Grove Village, Cook Co., IL Contact: Kevin Mangat (847) 439-8570 Ext. 1231
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5, 6, 7) - 4,000 gallons, (TK # 8) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 5, 6, 7, 8) - Hazardous Substance (ETHYL ACETATE)
- (e) *Type of leak detection being used:*
 - Tank:* (TK # 5, 6, 7, 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 with CSLD
 - Piping:* (TK # 5, 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 in tank sumps
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Chris Derro Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 05/21/2014
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)