



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020  
**Amended**

**FOR OFFICE USE ONLY**  
Facility # 2-045445  
Permit # 00797-2013INS  
Request Rec'd 08/13/2013  
Amended Date 11/12/2013  
Approval Date 8/13/2013 DS  
Permit Expires 2/13/2014

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Thornton's, Inc. 10101 Linn Station Road, P.O. Box 34230 Louisville, KY 40223 Contact: Patty Leonhardt (800) 928-8022	<b>(2) FACILITY</b> - name and address where tanks are located: Thornton Oil State rt. 83 & Foster (NE corner) Bensenville, Du Page Co., IL Contact:
---	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 1) - 20,000 gallons, (TK # 2, 4) - 6,000 gallons, (TK # 3) - 10,000 gallons, (TK # 5) - 30,000 gallons, (TK # 6) - 8,000 gallons
  - (b) Type of tanks:** (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass Brine Filled Double Wall Containment Solutions, (TK # 6) - (Installing) Fiberglass Double Wall Containment Solutions
  - (c) Type of piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 6) - (Installing) Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 6) - (Installing) Flexible Single Wall Piping OmegaFlex DEF-Trac non-corrosive flexible
  - (d) Product to be stored in each tank:** (TK # 1, 4) - Gasoline, (TK # 2) - E-85, (TK # 3, 5) - Diesel Fuel, **(TK # 6) - Diesel Exhaust Fluid (Non-Regulated)**
  - (e) Type of leak detection being used:**
    - Tank:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 350, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 Plus
    - Piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 Plus, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus in all submersible and all dispenser sumps
  - (f) Corrosion Protection being used:**
    - Tank:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Fiberglass Non-Corrosive
    - Piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Fiberglass Non-Corrosive, (TK # 6) - (Installing) Flexible Non-Corrosive
  - (g) Spill containment devices, piping and dispenser containment devices:** (TK # 1, 2, 3, 4, 5) - (Installing) Manhole Pre-manufactured EBW 705, (TK # 6) - (Installing) Manhole Pre-manufactured OPW 6211 SSR 15 remote fill spill containment
  - (h) Overfill prevention devices:** (TK # 1, 2, 3, 4, 5) - (Installing) Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube, (TK # 6) - (Installing) Overfill Alarm Veeder Root TLS 350 Plus
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**
- (5) GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) SPECIAL CONTINGENCIES:** The underground storage tank system for tank #2 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th notices regarding the storage and dispensing of alternative fuels. **Amendment request recieved on 11/7/2013 to change tank sized for tanks 5 & 6, change tank manufacturer and to show that tanks 5 & 6 are moving closer to the dispensing island**


**(7) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Hoyt Ary  
Phone: (708) 243-9081

Contractor Registration # IL-002275 Exp. 05/21/2014

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)