



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 3-018330
Permit # 01177-2013UPG
Request Rec'd 11/18/2013
Amended Date
Approval Date 11/20/2013 JC
Permit Expires 5/20/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Metropolitan Airport Authority 2430 69th Ave., Po Box 9009 Moline, IL 61265 Contact: Grothusen James (309) 764-9621	(2) FACILITY - name and address where tanks are located: Quad City Airport 2200 69th Ave. Moline, Rock Island Co., IL Contact: Bill Theofilis (309) 757-1741
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 13, 14) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 13, 14) - (Installing) Dispenser Sumps containment FRP to accommodate the removal and replacement of the existing product piping and islands, (TK # 13, 14) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC to replace all of the existing product piping within the existing trench from the tanks to each dispenser. The existing dispenser tops will be re-used; however, a new card reader will be installed.
- (d) *Product to be stored in each tank:* (TK # 13) - Diesel Fuel, (TK # 14) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 13, 14) - (Installing) Piping Sump Sensors Interstitial Monitoring OPW EECO 1500 discriminating sensors (Q0003-001) at the dispenser sumps only (**the contractor states there are existing sensors at the submersible sumps**).
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 13, 14) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Seneca Companies, Inc. 4140 East 14th Street, PO Box 3360 Des Moines, IA 50313	Contact Person: Aaron Miller Phone: (515) 264-4361 Contractor Registration # IL-598 Exp. 02/23/2014
---	---

Sincerely,

Jim Coffey

