



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-045522  
Permit # 01190-2013INS  
Request Rec'd 11/21/2013  
Amended Date  
Approval Date 11/21/2013 DS  
Permit Expires 5/21/2014

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                         |                                                                                                                                             |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>Transfuels, LLC<br>3760 Commons Lane<br>Salt Lake City, UT 84101<br><br>Contact: | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Blu McCook<br>9851 W 47th St<br>McCook, Cook Co., IL<br><br>Contact: |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|

**(3) INSTALLATION OF TANKS:**

**(a) Number and size of tanks being installed:** (TK # 1) - 20,000 gallons, (TK # 2) - 8,000 gallons

**(b) Type of tanks:** (TK # 1, 2) - (Installing) Fiberglass Double Wall Containment Solutions

**(c) Type of piping:** (TK # 1, 2) - (Installing) Flexible Double Wall Franklin Fueling Systems UPP

**(d) Product to be stored in each tank:** (TK # 1) - Diesel Fuel, (TK # 2) - Diesel Exhaust Fluid (Non-Regulated)

**(e) Type of leak detection being used:**

**Tank:** (TK # 1, 2) - (Installing) Interstitial Monitoring Incon TSP DIS, (TK # 1, 2) - (Installing) Automatic Tank Gauging Incon TS 550 with SCALD

**Piping:** (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS in all submersible and dispenser sumps, (TK # 1, 2) - (Installing) Mechanical Pressurized Line Leak Detection Vaporless LD 3000

**(f) Corrosion Protection being used:**

**Tank:** (TK # 1, 2) - (Installing) Fiberglass Non-Corrosive

**Piping:** (TK # 1, 2) - (Installing) Flexible Non-Corrosive

**(g) Spill containment devices, piping and dispenser containment devices:** (TK # 1, 2) - (Installing) Manhole Pre-manufactured EBW 705

**(h) Overfill prevention devices:** (TK # 1, 2) - (Installing) Overfill Drop Tube Valve EBW 708 Auto Limiter II

**(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**(6) SPECIAL CONTINGENCIES:**

|                                                                                                                                                  |                                                                                                              |
|--------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------|
| <b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b><br><br>Stenstrom Petroleum Services Group<br>2422 Center Street<br>Rockford, IL 61108 | Contact Person: Nate Meyer<br>Phone: (815) 398-6250<br><br>Contractor Registration # IL-1890 Exp. 03/07/2014 |
|--------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------|

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)