



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020  
**Amended**

FOR OFFICE USE ONLY

Facility # 6-012103  
Permit # 01139-2013UPG  
Request Rec'd 11/12/2013  
Amended Date 11/26/2013  
Approval Date 11/12/2013 DS  
Permit Expires 5/12/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                            |                                                                                                                                                                                                |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br>Gateway FS, Inc.<br>221 East Pine Street,<br>Red Bud, IL 62278<br>Contact: Greg Birchler (618) 282-3454 | <b>(2) FACILITY</b> - name and address where tanks are located:<br>Gateway FS - Sparta<br>615 South St. Louis Street<br>Sparta, Randolph Co., IL<br>Contact: Elizabeth McElveen (618) 317-6859 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 5) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 5) - (Installing) New "T" fitting under dispenser 1/2 to manifold product piping together. Dispenser has an existing sump and sensor
- (d) *Product to be stored in each tank:* (TK # 1, 5) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 1, 5) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 to replace existing TLS 350  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 1) - (Installing) Manhole Pre-manufactured OPW Edge 1C-3112D spill containment manhole
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Permit was amended to install new spill containment on tank #1

|                                                                                                                                                              |                                                                                                            |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b><br>Mid-South Steel Products, Inc.<br>2071 Corporate Circle Drive, PO Box 277<br>Cape Girardeau, MO 63703 | Contact Person: Billy Thorne<br>Phone: (573) 335-5529<br>Contractor Registration # IL-1194 Exp. 08/12/2014 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)