



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 4-006397
Permit # 01202-2013CAT
Request Rec'd 11/26/2013
Amended Date
Approval Date 11/26/2013 JC
Permit Expires 5/27/2014

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sandhu Petroleum Enterprises 212 Gridley Road Gridley, IL 61744 Contact: Mr. Singh (847) 361-7274	(2) FACILITY - name and address where tanks are located: Gridley Phillips 66 212 Gridley Road Gridley, McLean Co., IL Contact: Mr. Singh (309) 747-4182
---	--

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired:** (TK # 8) - 10,000 gallons, (TK # 9, 10) - 6,000 gallons
- (b) Type of tanks:**
- (c) Type of piping:**
- (d) Product to be stored in each tank:** (TK # 8, 9, 10) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:**
 - Piping:**
- (f) Corrosion Protection being used:**
 - Tank:**
 - Piping:** (TK # 8, 9, 10) - (Installing) Sacrificial Anode Cathodic Protection to any exposed steel piping / flex connectors / fittings as needed at each submersible sump only.
- (g) NACE certified designer:** **Certification number:**
- (h) Method of integrity assessment of tank(s) being used:**

- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Protanic, Inc. 658 North Progress Drive, PO Box 80265 Saukville, WI 53080	Contact Person: Frank Grebas Phone: (262) 268-1150 Contractor Registration # IL-1413 Exp. 08/29/2014
--	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)