



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 1-013037
 Permit # 01034-2013UPG
 Request Rec'd 10/09/2013
Amended Date 12/02/2013
 Approval Date 10/9/2013 JC
 Permit Expires 4/9/2014

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Jaswal Properties, Inc. 301 North Canal Street Annawan, IL 61234-4824 Contact: Vishal Jaswal (708) 369-7930</p> | <p>(2) FACILITY - name and address where tanks are located: Shop & Go 210 West Lincolnway Morrison, Whiteside Co., IL Contact: Crystal Ziglar (815) 772-2588</p> |
|--|---|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 2,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Fiberglass Single Wall Piping (this is for a new vent line only).
- (d) *Product to be stored in each tank:* (TK # 3) - Gasoline
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request was received 12/02/13 to correct the tank ID number (tank #3 received a new vent line as opposed to tank #2 - tank #2 was previously abandoned in place). This permit replaces expired permit #01141-2012UPG. Vent lines must be tested at 7 psi minimum or at a pressure recommended by the manufacturer.

| | |
|--|--|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> | |
| <p>Pipeco, Inc. 610 29th Street Bettendorf, IA 52722</p> | <p>Contact Person: Art Wentworth Phone: (563) 344-0700 Contractor Registration # IL-2034 Exp. 09/28/2014</p> |

Sincerely,

Jim Coffey

