



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 4-031871
Permit # 01259-2013ENT
Request Rec'd 12/18/2013
Amended Date
Approval Date 12/18/2013 JC
Permit Expires 6/18/2014

Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Martin & Bayley, Inc. 1311 A. W. Main Street, Carmi, IL 62821 Contact: Troy Deitz (618) 382-2334	(2) FACILITY - name and address where tanks are located: Hucks #186 701 Cleveland Street Heyworth, McLean Co., IL Contact: Mark Bayley (309) 473-2023
--	--

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered:* (TK # 3) - 10,000 gallons
 - (b) Type of tanks:* Fiberglass
 - (c) Product stored in each tank:* (TK # 3) - Gasoline
 - (d) Reason for tanks being entered:* See contingencies section.
 - (e) Manway accessible at grade:* Contractor states a manway will be installed.
- (4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**
- (5) SPECIAL CONTINGENCIES: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. Contractor needs to enter / clean/ and inspect this tank for damage. Also, the tank has to be cut on so that a manway can be installed. The Storage Tank Safety Specialist must be scheduled to be on site when the tanks are penetrated. Tanks will be entered by employees from the tank manufacturer, with proper OSHA training , to inspect and evaluate the integrity of these fiberglass tanks. Appropriate confined space entry permit is required from OSHA Scheduling of tank penetration with our office is required, with qualified employee from the permitted contractor present to supervise this project.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Superior Acquisition, LLC dba Superior Equipment Company 7525-A Sussex St. Louis, MO 63143	Contact Person: Greg Spiros Phone: (314) 644-6000 Contractor Registration # IL-002394 Exp. 02/26/2015
---	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)