



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 7-011587  
Permit # 01262-2013UPG  
Request Rec'd 12/18/2013  
Amended Date  
Approval Date 12/19/2013 JC  
Permit Expires 6/19/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Martin & Bayley, Inc. 1311 A. W. Main Street, Carmi, IL 62821 Contact: Troy Deitz (618) 382-2334	<b>(2) FACILITY</b> - name and address where tanks are located: Hucks Food & Fuel #366 3228 South Park Avenue Herrin, Williamson Co., IL Contact: Shawna Coley (618) 993-0343
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 6,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC from the tank to the first dispenser only (approximately 40') to replace the existing run of piping.

(d) *Product to be stored in each tank:* (TK # 6) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the submersible sump and at the first dispenser sump only.

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 6) - (Installing) Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: (812) 425-4137 Contractor Registration # IL-646 Exp. 04/02/2014
--------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)