



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 4-024557
Permit # 01219-2013CAT
Request Rec'd 12/04/2013

Amended Date 12/19/2013

Approval Date 12/4/2013 JC
Permit Expires 6/4/2014

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Raspinder Singh
2522 Kings Court
Terre Haute, IN 47807

Contact: Raspinder Singh (812) 232-7021

(2) FACILITY - name and address where tanks are located:

Khaira Travel Mart, Inc. d/b/a Jiffy Mini Marts
1804 IL Highway 1, I-70 and Route 1
Marshall, Clark Co., IL

Contact: Cassady Glidewell (217) 826-6040

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 4, 5) - 8,600 gallons, (TK # 6) - 12,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 4, 5) - Gasoline, (TK # 6) - E-85

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank: (TK # 4, 5, 6) - (Installing) additional Sacrificial Anode Cathodic Protection to the existing stip 3 tanks.

Piping:

(g) *NACE certified designer:*

Certification number:

(h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request was received 12/19/13 to add tank #6 to the permit. The underground storage tank system for tank #6 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Bolin Enterprises, Inc.
506 North East 15th Street, PO Box 70
Casey, IL 62420

Contact Person: Scott Justice

Phone: (217) 932-4533

Contractor Registration # IL-002333 Exp. 10/10/2014

Sincerely,

Jim Coffey

