



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 4-031871
Permit # 01266-2013REM
Request Rec'd 12/20/2013
Amended Date
Approval Date 12/20/2013 JC
Permit Expires 6/20/2014

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Martin & Bayley, Inc. 1311 A. W. Main Street, Carmi, IL 62821 Contact: Troy Deitz (618) 382-2334	(2) FACILITY - name and address where tanks are located: Hucks #186 701 Cleveland Street Heyworth, McLean Co., IL Contact: Mark Bayley (309) 473-2023
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1, 2) - 10,000 gallons, (TK # 3, 4) - 15,000 gallons
- (b) *Description/location of piping being removed:*
- (c) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 1) - 11/19/2013, (TK # 2, 3, 4) - 12/19/2013

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES:** **Removing tanks and associated piping. This is an expedited permit due to one tank having floated and compromising the entire tank field.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Seneca Companies, Inc. 458 N. Highway 48 Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: (217) 468-2393 Contractor Registration # IL-598 Exp. 02/23/2014
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)