



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**Permit for Emergency Repair Request on  
12/28/2013**

**FOR OFFICE USE ONLY**

Facility # 2-016786  
Permit # 00018-2014UPG  
Request Rec'd 01/10/2014  
Amended Date  
Approval Date 1/10/2014 JC  
**Permit Expires 1/27/2014**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: BMC Oil, Inc. 1331 N. Farnsworth Aurora, IL 60505 Contact: Albert Cheung (630) 851-5505	<b>(2) FACILITY</b> - name and address where tanks are located: Farnsworth Phillip 66 1331 N. Farnsworth Aurora, Kane Co., IL Contact: Albert Cheung (630) 851-5505
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 12,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1, 2, 3) - (Installing) partial Fiberglass Single Wall Piping A.O. Smith near the southeast dispenser. There will be less than 20' and less than 50% per piping run that will be replaced due to horizontal drilling damage.

(d) *Product to be stored in each tank:* (TK # 1, 3) - Gasoline, (TK # 2) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Emergency request was received 12/28/14. The final inspection must be scheduled by 01/27/14.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611	Contact Person: Brian McCormick Phone: (309) 222-5293 Contractor Registration # IL-002393 Exp. 12/12/2014
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)