



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**FOR OFFICE USE ONLY**  
 Facility # 2-014591  
 Permit # 00115-2014UPG  
 Request Rec'd 02/11/2014  
 Amended Date  
 Approval Date 2/11/2014 JC  
 Permit Expires 2/27/2014

## Permit for Emergency Repair Request on 02/08/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Speedway, LLC          P.O. Box 1500          Springfield, OH 45501-1500          Contact: Michelle Henson (937) 863-7340</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Speedway 7610          1975 Stunkel Road          University Park, Will Co., IL          Contact: Kevin Loggins (708) 335-0600</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6) - (Installing) Flex Connector Steel at the submersible sump only, to replace the existing leaking flex connector.
- (d) *Product to be stored in each tank:* (TK # 6) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Request was received 02/09/14. The final inspection must be scheduled by 02/27/14.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          DRW Services, Inc.          600 East Joe Orr Road          Chicago Heights, IL 60411</p>	<p>Contact Person: Douglas Harmon          Phone: (708) 758-3222 Ext. 12          Contractor Registration # IL-194 Exp. 03/10/2014</p>
--	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)