



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 3-034970
Permit # 01113-2013UPG
Request Rec'd 10/31/2013
Amended Date 02/11/2014
Approval Date 10/31/2013 JC
Permit Expires 4/30/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 4080 W. Johnson Moore Pike, Columbus, IN 42701-0347 Contact: Matthew Jordan (812) 379-9227	(2) FACILITY - name and address where tanks are located: Circle K #1331 1619 E. Jackson Street Macomb, McDonough Co., IL Contact: Nicole Anderson (309) 295-8367
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1) - 6,000 gallons, **(TK # 2) - 10,000 gallons**, (TK # 3) - 12,000 gallons
- (b) Type of tanks:**
- (c) Type of piping:**
- (d) Product to be stored in each tank:** (TK # 1, 3) - Gasoline, **(TK # 2) - Diesel Fuel**
- (e) Type of leak detection being used:**
 - Tank:**
 - Piping:**
- (f) Corrosion Protection being used:**
 - Tank:**
 - Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices:**
- (h) Overfill prevention devices:** (TK # 1, **2**, 3) - (Installing) Overfill Drop Tube Valve OPW 71SO-400C to replace the existing ball float valves.
- (i) Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES: Amendment request to add tank #2 to this permit was received 02/11/14.**

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139	Contact Person: Justin Burkemper Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp. 03/26/2014
--	--

Sincerely,

Jim Coffey

