



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 7-045481
Permit # 00111-2014INS
Request Rec'd 02/11/2014
Amended Date
Approval Date 2/11/2014 DS
Permit Expires 8/11/2014

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Wortman Meyer Properties, LLC 1502 West Fayette Effingham, IL 62401</p> <p>Contact: Lisa Wortman (217) 342-1000</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Mach I 44 N Commercial St Harrisburg, Saline Co., IL</p> <p>Contact:</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 1, 5) - 8,000 gallons, (TK # 2) - 12,000 gallons, (TK # 3) - 10,000 gallons, (TK # 4) - 20,000 gallons
- (b) Type of tanks:** (TK # 1, 2, 3, 4, 5) - (Installing) Composite Double Wall Glasteel II
- (c) Type of piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC product piping from tanks to dispensers, as well as from DEF tank to middle Diesel dispenser as shown in drawing, (TK # 1, 2, 3, 4, 5) - (Installing) Chase Secondary Containment A.P.T. Poly Tech DCT-400 to all dispensers as well as a run for future product considerations from tank #3 to gasoline islands per drawing, (TK # 1, 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX between Diesel tanks for a syphon line
- (d) Product to be stored in each tank:** (TK # 1, 2) - Diesel Fuel, (TK # 3, 4) - Gasoline, (TK # 5) - Diesel Exhaust Fluid
(Non-Regulated)
- (e) Type of leak detection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5) - (Installing) Interstitial Monitoring Veeder Root TLS 450, (TK # 1, 2, 3, 4, 5) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 with CSLD
 - Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 450 , (TK # 1, 2, 3, 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 in all dispenser sumps and in all submersible sumps
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5) - (Installing) Composite Non-Corrosive
 - Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Flexible Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:** (TK # 1, 2, 3, 4, 5) - (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) Overfill prevention devices:** (TK # 1, 2, 3, 4, 5) - (Installing) Overfill Drop Tube Valve OPW 71SO

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
1458 Collins Street
St. Louis, MO 63102

Contact Person: Terry Smith
Phone: (314) 241-3767

Contractor Registration # IL-002402 Exp. 02/10/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)