



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Permit for Emergency Repair Request on 02/14/2014

### FOR OFFICE USE ONLY

Facility # 2-016467  
Permit # 00144-2014UPG  
Request Rec'd 02/20/2014  
Amended Date  
Approval Date 2/20/2014 JC  
Permit Expires 3/6/2014

### Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Kanakary Corporation 2039 W. Maple Ave. Mundelein, IL 60060  Contact: Prince Eapon (847) 970-9629	<b>(2) FACILITY</b> - name and address where tanks are located:  Ivanhoe Citgo 2029 W. Maple Ave. Mundelein, Lake Co., IL  Contact: Prince (847) 970-9629
--	---

### **(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 5) - 12,000 gallons
  - (b) Type of tanks:*
  - (c) Type of piping:* (TK # 5) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX (approx. 3' to 4') to repair a short damaged section of piping near dispenser #3/4 only. The damage is also within the vicinity of a piping elbow (see site plan).
  - (d) Product to be stored in each tank:* (TK # 5) - Gasoline
  - (e) Type of leak detection being used:*
    - Tank:*
    - Piping:*
  - (f) Corrosion Protection being used:*
    - Tank:*
    - Piping:* (TK # 5) - (Installing) Fiberglass Non-Corrosive
  - (g) Spill containment devices, piping, and dispenser containment devices:*
  - (h) Overfill prevention devices:*
  - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**
- (5) SPECIAL CONTINGENCIES: All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 03/06/14. Emergency request was received 02/14/14.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Superior Petroleum Marketers, Inc. 2336 Albright Lane , P. O.Box 4648 Wheaton, IL 60189-4648	Contact Person: Steve Tuttle Phone: (630) 588-1198  Contractor Registration # IL-2087 Exp. 02/04/2016
---	--

Sincerely,

Jim Coffey

