



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 5-031556
 Permit # 00176-2014REM
 Request Rec'd 03/06/2014
 Amended Date
 Approval Date 3/6/2014 JC
 Permit Expires 9/8/2014

Removing piping only

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|---|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Memorial Medical Center 701 North 1st Street Springfield, IL 62781 Contact: Buddy King, (217) 788-3170</p> | <p>(2) FACILITY - name and address where tanks are located: Memorial Medical Center 701 North 1st Street Springfield, Sangamon Co., IL Contact: Rich Ballweg (217) 788-3170</p> |
|---|--|

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 3, 4) - 20,000 gallons
- (b) *Description/location of piping being removed:* **See contingencies section.**
- (c) *Product stored in each tank:* (TK # 3, 4) - Diesel Fuel
- (d) *Reason of tanks being removed:* **Tanks will remain existing (see contingencies section).**
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 3), (TK # 4)

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES: Removing all suction and return product lines from the tanks to the to the building. The tanks and vent piping will remain existing (see permit #00177-2014UPG and 00108-2014INS for further info).

| | |
|--|---|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> | |
| <p>Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554</p> | <p>Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2016</p> |

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)