



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-031556
Permit # 00177-2014UPG
Request Rec'd 03/06/2014
Amended Date
Approval Date 3/6/2014 JC
Permit Expires 9/8/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Memorial Medical Center 701 North 1st Street Springfield, IL 62781 Contact: Buddy King, (217) 788-3170	(2) FACILITY - name and address where tanks are located: Memorial Medical Center 701 North 1st Street Springfield, Sangamon Co., IL Contact: Rich Ballweg (217) 788-3170
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3, 4) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3, 4) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX supply and return lines from the tanks to a transition sump located just outside of the new pump room.
- (d) *Product to be stored in each tank:* (TK # 3, 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 3, 4) - (Installing) Piping Sump Sensor Interstitial Monitoring Veeder Root TLS 350 at the transition sump only (there are existing sensors at the tank sumps) , (TK # 3, 4) - (Installing) American with Sensors/No Test Suction
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 3, 4) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** See permit #00176-2014REM and 00108-2014INS for further job details at this site.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2016
---	--

Sincerely,

Jim Coffey

