



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-020308  
Permit # 00138-2014UPG  
Request Rec'd 02/19/2014  
**Amended Date 03/06/2014**  
Approval Date 2/19/2014 JC  
Permit Expires 8/19/2014

## Amended

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Evipidid Gogos 3613 North Harlem Chicago, IL 60634  Contact: George Kanellos (847) 420-9323	<b>(2) FACILITY</b> - name and address where tanks are located:  E & D Citgo, Inc. 4555 North Nagle Harwood Heights, Cook Co., IL  Contact: Mike Milella (708) 667-0506
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 3) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 3) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive between dispensers 5/6 and 1/2. **Also, the piping run between the submersible pump for tank #3 and dispenser #1/2 will be replaced.**
- (d) *Product to be stored in each tank:* (TK # 1, 3) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:**
  - Piping:** (TK # 1, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300 under dispensers 1/2 and 5/6 only (**our records indicate there is an existing sensor at the submersible sump for tank #3).**
- (f) *Corrosion Protection being used:*
  - Tank:**
  - Piping:** (TK # 1, 3) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** This permit was originally approved by Dan Starks. Amendment request was received 03/06/14 to include replacing the product line from tank #3 to dispenser #1/2 (according to our records there is an existing submersible sump sensor).

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 243-9081  Contractor Registration # IL-002275 Exp. 05/21/2014
--	--

Sincerely,

Jim Coffey

