



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 1-042306
 Permit # 00183-2014UPG
 Request Rec'd 03/07/2014
 Amended Date
 Approval Date 3/10/2014 JC
 Permit Expires 3/24/2014

Permit for Emergency Repair Request on 02/19/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. 10601 North Pennsylvania Avenue Oklahoma City, OK 73120</p> <p>Contact: Michael Franklin (405) 302-6640</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Love's Travel Stop #322 13477 Quality Drive Roscoe, Winnebago Co., IL</p> <p>Contact: Stephen Alberts (815) 389-1923</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) partial Fiberglass Double Wall Ameron to repair two sections of leaking piping (contractor replaced a 90 degree elbow, a coupling, and approximately 8" to 10" short section of piping that supplies island #4 and #5 - see site plan for location). The coupling leak was found approximately 40' from island #1. The line comes from a common blending transition sump located near the tank field.
- (d) *Product to be stored in each tank:* (TK # 1) - Diesel Fuel
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping: (TK # 1) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Emergency request was received 02/19/14. The final inspection must be scheduled by 03/24/14. Each tank must have an independent vent line that extends aboveground. Manifolding vent lines underground is not allowed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: Greg Berkheimer Phone: (608) 249-2881 Contractor Registration # IL-1318 Exp. 10/29/2014

Sincerely,

James J. Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)