



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Permit for Emergency Repair Request on 02/27/2014

FOR OFFICE USE ONLY

Facility # 7-015252
Permit # 00178-2014UPG
Request Rec'd 03/06/2014
Amended Date
Approval Date 3/26/2014 JC
Permit Expires 4/9/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Aving-Rice, LLC P.O. Box 806, Effingham, IL 62401 Contact: David George (913) 599-5800	(2) FACILITY - name and address where tanks are located: Aving-Rice, LLC d/b/a Jumpin' Jimmy's #84 610 E. Main Street Carmi, White Co., IL Contact: Mariah Brooks (913) 599-5800
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2) - 6,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 2) - (Installing) Fiberglass Single Wall Piping A.O. Smith vent piping to replace the entire existing vent line for this tank.
- (d) Product to be stored in each tank:* (TK # 2) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK #2) - (Installing) non-corrosive fiberglass.
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:** This request was initially sent in for tank #1; however, after further investigation regarding the correct tank ID #'s for this site, it appears this repair is for tank #2 as opposed to tank #1. There are numerous inconsistencies in the file concerning the tank ID #'s (after reviewing past documents, based off mathematical probability, it appears the tank vent line is for tank #2). See also permit #00189-2014ABN for further reference. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Emergency repair request was received 02/27/14. The final inspection must be scheduled by 04/09/14.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Bolin Enterprises, Inc. 506 North East 15th Street, PO Box 70 Casey, IL 62420	Contact Person: Scott Justice Phone: (217) 932-4533 Contractor Registration # IL-002333 Exp. 10/10/2014
--	---

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)