



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<p align="center"><u>FOR OFFICE USE ONLY</u></p> Facility # 2-036299 Permit # 00260-2014UPG Request Rec'd 03/31/2014 Amended Date Approval Date 4/1/2014 DS Permit Expires 10/1/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> State Oil Company 31366 N. Hwy. 45 Libertyville, IL 60048 Contact: Mark Stang (847) 680-5831	<p>(2) FACILITY - name and address where tanks are located:</p> Green Bay 38947 North Green Bay Road Beach Park, Lake Co., IL Contact: Mary Ann Kaski (847) 599-0321
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 7, 8) - 10,000 gallons, (TK # 9) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 7, 8, 9) - (Installing) Partial Fiberglass Single Wall Piping Ameron to replace "T's"
- (d) *Product to be stored in each tank:* (TK # 7, 8, 9) - Gasoline
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping: (TK # 7, 8, 9) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) **SPECIAL CONTINGENCIES:** Due to a road widening project, dispenser #7/8 is being removed and piping "T's", which supplied dispenser, being replaced with regular piping.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> DRW Services, Inc. 600 East Joe Orr Road Chicago Heights, IL 60411	Contact Person: Douglas Harmon Phone: (708) 758-3222 Ext. 12 Contractor Registration # IL-194 Exp. 03/10/2016
---	---

Sincerely,

Daniel Starks