



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-022814
Permit # 00308-2014UPG
Request Rec'd 04/14/2014
Amended Date
Approval Date 4/15/2014 JC
Permit Expires 10/15/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc.        446 Morris Ave., P.O. Box 777        Mundelein, IL 60060-1919</p> <p>Contact: Matt Graham (847) 507-0254</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Morton Grove Bp (SS# 286)        8801 Waukegan Road        Morton Grove, Cook Co., IL</p> <p>Contact: Erminio Caporale (847) 966-4448</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 2) - 6,000 gallons, (TK # 3) - 8,000 gallons, (TK # 4) - 10,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 2, 3, 4) - (Installing) partial Fiberglass Single Wall Piping to accommodate the installation of a dispenser sump under the farthest west dispenser only (each piping section length will be approximately 5' to accomplish this task). , (TK # 2, 3, 4) - (Installing) Dispenser Sump containment FRP under the farthest west dispenser only., (TK # 2, 3, 4) - (Installing) Shear Valves (total of three under the farthest west dispenser only) , (TK # 2, 3, 4) - (Installing) Flex Connector Steel (total of three under the farthest west dispenser only).
- (d) **Product to be stored in each tank:** (TK # 2, 3, 4) - Gasoline
- (e) **Type of leak detection being used:**  
**Tank:**  
**Piping:** (TK # 2, 3, 4) - (Installing) Piping Sump Sensor Interstitial Monitoring Veeder Root TLS 350 at the farthest west dispenser sump only.
- (f) **Corrosion Protection being used:**  
**Tank:**  
**Piping:**
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overflow prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>DRW Services, Inc.        600 East Joe Orr Road        Chicago Heights, IL 60411</p>	<p>Contact Person: Ray Kirchner        Phone: (708) 758-3222 Ext. 12</p> <p>Contractor Registration # IL-194 Exp. 03/10/2016</p>
--	--

Sincerely,

Jim Coffey

