



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020  
**EMERGENCY REPAIR**

<u>FOR OFFICE USE ONLY</u>
Facility # 1-042306
Permit # 00334-2014UPG
Request Rec'd 04/21/2014
Amended Date
Approval Date 4/21/2014 DS
Permit Expires 5/5/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Love's Travel Stops &amp; Country Stores, Inc.          P.O. Box 26210          Oklahoma City, OK 73126          Contact: Michael Franklin (405) 302-6640</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Love's Travel Stop #322          13477 Quality Drive          Roscoe, Winnebago Co., IL          Contact: Stephen Alberts (815) 389-1923</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Partial Fiberglass Double Wall Ameron to repair a leaking piping coupling as shown in site plan
- (d) *Product to be stored in each tank:* (TK # 1) - Diesel Fuel
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:* (TK # 1) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). This permit replaces previous permit #00183-2014UPG which was not executed due to missing final inspection

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: Greg Berkheimer Phone: (608) 249-2881 Contractor Registration # IL-1318 Exp. 10/29/2014

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Division File  
 (Rev. - 9/10)