



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-021159
Permit # 00329-2014UPG
Request Rec'd 04/17/2014
Amended Date
Approval Date 4/22/2014 JC
Permit Expires 10/22/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Riteline Properties, LLC 200 W. Higgins Rd. Schaumburg, IL 60195</p> <p>Contact: Robert Stambolic (847) 361-5927</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Shell Service Station 2501 Meacham Road Schaumburg, Cook Co., IL</p> <p>Contact: Harry Psarros (847) 922-6376</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7) - 15,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6, 7) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX product piping to replace all existing product piping (the existing vent lines will remain).
- (d) *Product to be stored in each tank:* (TK # 6, 7) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:* (TK # 6, 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at both submersible sumps and at four dispenser sumps - two center dispensers and two farthest east dispensers (see permit #00330-2014INS for further details).
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 6, 7) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overflow prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Also, see permit #00330-2014INS for further information regarding work at this site.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611</p>	<p>Contact Person: Brian McCormick Phone: (309) 222-5293</p> <p>Contractor Registration # IL-002393 Exp. 12/12/2014</p>
---	--

Sincerely,

Jim Coffey

