



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<p align="center"><u>FOR OFFICE USE ONLY</u></p> <p>Facility # 2-036299          Permit # 00338-2014UPG          Request Rec'd 04/22/2014          Amended Date          Approval Date 4/22/2014 JC          Permit Expires 10/22/2014</p>
--

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>State Oil Company          31366 N. Hwy. 45          Libertyville, IL 60048</p> <p>Contact: Mark Stang (847) 680-5831</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Green Bay          38947 North Green Bay Road          Beach Park, Lake Co., IL</p> <p>Contact: Mary Ann Kaski (847) 599-0321</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 6,000 gallons, (TK # 7, 8) - 10,000 gallons, (TK # 9) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6, 7, 8, 9) - (Installing) partial Fiberglass Single Wall Piping Ameron at the localized area of the submersible to accommodate replacement of the sumps only, (TK # 6, 7, 8, 9) - (Installing) Submersible Sumps containment FRP to replace existing submersible sumps, (TK # 6, 7, 8, 9) - (Installing) Flex Connector Steel at the submersible pump areas only, (TK # 6, 7, 8, 9) - (Installing) Positive Shutoff Valves at the submersible pump areas only.
- (d) *Product to be stored in each tank:* (TK # 6) - Diesel Fuel, (TK # 7, 8, 9) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>DRW Services, Inc.          600 East Joe Orr Road          Chicago Heights, IL 60411</p>	<p>Contact Person: Douglas Harmon          Phone: (708) 758-3222 Ext. 12</p> <p>Contractor Registration # IL-194 Exp. 03/10/2016</p>
--	--

Sincerely,

Jim Coffey

