



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 6-033229
Permit # 00112-2014UPG
Request Rec'd 02/11/2014
Amended Date 04/22/2014
Approval Date 2/11/2014 JC
Permit Expires 8/11/2014

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Moto, Inc. 721 W. Main St., P.O. Box 122 Belleville, IL 62222-0122</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>O'Fallon Moto Mart 8401 US Highway 50, US 50 & Route 158 Lebanon, St. Clair Co., IL</p> <p>Contact: Rob Whittington (618) 233-6754</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2) - (Installing) Submersible Sump containment FRP to replace the existing sump, **(TK # 2) - (Installing) Transition Sump FRP fiberglass adjacent to the new submersible sump , (TK # 2) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P175SC (Inspector note: one of the piping runs from the tank sumpto dispensers #1/2 and #3/4 was found to have a fitting that needs replaced. This will require the contractor to cut the piping back approximately one foot and consequently the existing flexible pipe will not be long enough to enter said tank sump. The contractor will install a transition sump adjacent to the new tank sump in order to couple a new piece of flexible piping to the existing piping and then enter the new submersible tank sump).**

(d) *Product to be stored in each tank:* (TK # 2) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at the new transition sump only

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overflow prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES: Amendment request was received 04/22/14 to include installation of a transition sump with sensor and a short partial section of piping.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
1458 Collins Street
St. Louis, MO 63102

Contact Person: Terry Smith
Phone: (314) 241-3767

Contractor Registration # IL-002402 Exp. 02/10/2016

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)