



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-017859
Permit # 00381-2014INS
Request Rec'd 05/01/2014
Amended Date
Approval Date 5/1/2014 JC
Permit Expires 11/3/2014

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: South Suburban Hospital 17800 South Kedzie Avenue Hazel Crest, IL 60429 Contact: Joe Daniel (708) 213-3097	(2) FACILITY - name and address where tanks are located: South Suburban Hospital 17800 South Kedzie Avenue Hazel Crest, Cook Co., IL Contact: George Nelson (708) 213-3097
--	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 8) - 15,000 gallons

(b) Type of tanks: (TK # 8) - (Installing) Fiberglass Double Wall XERXES

(c) Type of piping: (TK # 8) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX supply and return product lines from the tank to the transition sump (also, there will be two submersible pumps that will be tee'd together at the submersible tank sump). , (TK # 8) - (Installing) Transition Sump FRP fiberglass located just outside of the building wall , (TK # 8) - (Installing) Fiberglass Single Wall Piping Ameron vent piping.

(d) Product to be stored in each tank: (TK # 8) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 , (TK # 8) - (Installing) Interstitial Monitoring Veeder Root TLS 350

Piping: (TK # 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 , (TK # 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the transition sump (1ea.), and one at each submersible pump (2 ea.).

(f) Corrosion Protection being used:

Tank: (TK # 8) - (Installing) Fiberglass Non-Corrosive

Piping: (TK # 8) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices, piping and dispenser containment devices: (TK # 8) - (Installing) Manhole Pre-manufactured EBW 715

(h) Overfill prevention devices: (TK # 8) - (Installing) Overfill Drop Tube Valve OPW 71SO

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES: According to the site plan, the tank is approximately 5' from the service road. The contractor and owner must ensure there will be no load projection to the tank from vehicles travelling this service road. The line leak detectors and the interstitial sensors must only send an audible and visual alarm upon detection of a release, and NOT be wired to shut down the submersible pumps.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
2511 West Schaumburg Road, #358
Schaumburg, IL 60194

Contact Person: Robert Sumoski
Phone: (630) 497-9009

Contractor Registration # IL-002345 Exp. 05/16/2014

Sincerely,

A handwritten signature in cursive script, reading "Jim Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)