



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-010854
Permit # 00385-2014INS
Request Rec'd 05/02/2014
Amended Date
Approval Date 5/5/2014 JC
Permit Expires 11/5/2014

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Alfred Karalli 6840 West Howard Niles, IL 60714 Contact: Alfred Karalli (773) 430-2123	(2) FACILITY - name and address where tanks are located: Harlem & Palmer Mobil 2144 North Harlem Elmwood Park, Cook Co., IL Contact: Alfred Karalli (773) 744-5801
--	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 6) - 14,000 gallons, and one compartment tank consisting of the two following:
(TK # 7, 8) - 6,000 gallons each
- (b) **Type of tanks:** (TK # 6, 7, 8) - (Installing) Composite Double Wall Glasteel II
- (c) **Type of piping:** (TK # 6, 7, 8) - (Installing) Fiberglass Single Wall Piping Ameron vent piping, (TK # 6, 7, 8) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX product piping.
- (d) **Product to be stored in each tank:** (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel
- (e) **Type of leak detection being used:**
Tank: (TK # 6, 7, 8) - (Installing) Interstitial Monitoring Veeder Root TLS 350, (TK # 6, 7, 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 probes only (contractor states they will re-use the existing Gilbarco EMC console from the old tank system).
Piping: (TK # 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all submersible sumps and at all dispenser sumps, (TK # 6, 7, 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) **Corrosion Protection being used:**
Tank: (TK # 6, 7, 8) - (Installing) Composite Non-Corrosive
Piping: (TK # 6, 7, 8) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:** (TK # 6, 7, 8) - (Installing) Manhole Pre-manufactured OPW 1C-2100-DEVR
- (h) **Overfill prevention devices:** (TK # 6, 7, 8) - (Installing) Overfill Drop Tube Valve OPW 71-SO 4010C Overfill drop tube
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

- (6) **SPECIAL CONTINGENCIES:** See permits 00386-2014ABN and 00384-2014REM for more complete details of the work at this site.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue	Contact Person: Hoyt Ary Phone: (708) 243-9081
---	---

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)