



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-044884
Permit # 00348-2014UPG
Request Rec'd 04/23/2014
Amended Date
Approval Date 4/24/2014 JC
Permit Expires 10/24/2014

REVISED

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 Oklahoma City, OK 73126 Contact: Michael Franklin (405) 302-6640</p>	<p>(2) FACILITY - name and address where tanks are located: Love's Travel Stop #395 3407 South US Rts. 45 and 52 Kankakee, Kankakee Co., IL Contact: Brad Whitler (815) 929-1549</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 8) - 8,000 gallons, (TK # 2) - 12,000 gallons, (TK # 3, 4, 5, 6, 7) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4, 5, 6) - Diesel Fuel, (TK # 7) - B-99, (TK # 8) - Diesel Exhaust Fluid (Non-Regulated)
- (e) *Type of leak detection being used:*

Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 console only, to replace the existing TLS 450 console. The existing probes and sensors will remain.

Piping:

- (f) *Corrosion Protection being used:*

Tank:

Piping:

- (g) *Spill containment devices, piping, and dispenser containment devices:*

- (h) *Overfill prevention devices:*

- (i) *Manway accessible at grade:*

- (4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

- (5) **SPECIAL CONTINGENCIES: This permit is being revised / corrected to show that the existing TLS-450 console is being replaced by the TLS-350 console (not vise-versa as was originally permitted). All other equipment will remain existing. This permit was originally approved by Dan Starks.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2016

James J. Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)