



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-032189
Permit # 00413-2014UPG
Request Rec'd 05/08/2014
Amended Date
Approval Date 5/9/2014 JC
Permit Expires 11/10/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          O J's Oil Enterprises, Ltd.          641 N. Roselle Rd.          Roselle, IL 60172          Contact: Jamil Auchana</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Circle J's Shell          641 North Roselle Road          Roselle, Du Page Co., IL          Contact: Jamil Auchana (630) 529-1777</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 12,000 gallons
  - (b) *Type of tanks:*
  - (c) *Type of piping:* (TK # 1) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P175SC from the submersible to the first dispenser (south east dispenser closest to tank field) only. This piping will be installed through existing chase piping.
  - (d) *Product to be stored in each tank:* (TK # 1, 3) - Gasoline, (TK # 2) - Bio-Diesel
  - (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the first dispenser only (the south east dispenser closest to the tank field only). Tanks 1,2,3 supply this first dispenser.
  - (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 1) - (Installing) partial Flexible Non-Corrosive within existing secondary chase piping.
  - (g) *Spill containment devices, piping, and dispenser containment devices:*
  - (h) *Overfill prevention devices:*
  - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** The underground storage tank system for tank #2 and #4 must be compatible with bio-diesel, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th notices regarding the storage and dispensing of alternative fuels. Contractor states there is an existing sensor at the submersible pump for tank #1. The first dispenser is supplied by tanks 1,2,3.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611	Contact Person: Brian McCormick Phone: (309) 222-5293 Contractor Registration # IL-002393 Exp. 12/12/2014

Sincerely,

*Jamie J. Coffey*

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)