



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 3-002901
Permit # 00445-2014INS
Request Rec'd 05/15/2014
Amended Date
Approval Date 5/15/2014 JC
Permit Expires 11/17/2014

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Bonnett Wholesale Florist, Inc. 119 East 8th Street Milan, IL 61264 Contact: Robert Bonnett (309) 787-4401	(2) FACILITY - name and address where tanks are located: Bonnett Wholesale Florist, Inc. 119 East 8th Street Milan, Rock Island Co., IL Contact: Robert Bonnett (309) 787-4401
--	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 4, 5, 6) - 4,000 gallons
- (b) Type of tanks:** (TK # 4, 5, 6) - (Installing) Composite Double Wall Glasteel II
- (c) Type of piping:** (TK # 4, 5, 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC
- (d) Product to be stored in each tank:** (TK # 4, 5) - Diesel Fuel, (TK # 6) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:** (TK # 4, 5, 6) - (Installing) Automatic Tank Gauging EBW Auto-Stik 950 (contractor is reusing the existing ATG console and probes from the old tank system), (TK # 4, 5, 6) - (Installing) Interstitial Monitoring Incon TSP ULS
 - Piping:** (TK # 4, 5, 6) - (Installing) European with No Test Req Suction
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 4, 5, 6) - (Installing) Composite Non-Corrosive
 - Piping:** (TK # 4, 5, 6) - (Installing) Flexible Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:** (TK # 4, 5, 6) - (Installing) Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices:** (TK # 4, 5, 6) - (Installing) Overfill Drop Tube Valve EBW 708 Auto Limiter II

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

- (5) GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

- (6) SPECIAL CONTINGENCIES: This permit replaces permit #01230-2013INS due to near expiration date (more time is needed to complete this job - tank delivery problems). This new permit and site plan is identical to the original. Dan Starks approved the original permit.**

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Illowa Enterprises, Inc. 2703 4th Avenue Moline, IL 61265	Contact Person: Rob Vyncke Phone: (309) 762-1729 Contractor Registration # IL-981 Exp. 05/01/2016
---	--

Sincerely,

A handwritten signature in cursive script, reading "Jim Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)